



# Lead Testing in School Drinking Water



## Location:

Holley Central School District  
Middle / High School  
Holley, New York 14470

## Prepared for:

Holley Central School District  
3800 North Main Street  
Holley, New York 14470

LaBella Project No. 2202182

October 26, 2020

## Table of Contents

	Page No.
I. Background	1
II. Project Description	1
III. Sampling Procedures and Summary of Results	2
IV. Response and Recommendations	3
V. Reporting and Record Keeping	3
 Appendix A – Detailed Results Spreadsheet	
 Appendix B – Laboratory Analytical Reports	
 Appendix C – Licenses and Certifications	



## **I. BACKGROUND**

Under Subpart 67-4 of the New York Codes, Rules and Regulations, Title X, “all school districts and boards of cooperative educational services are required to test potable water for lead contamination, and to develop and implement a lead remediation plan, where applicable.”

The Subpart 67-4 testing requirement was first promulgated under emergency legislation in 2016, and was subsequently signed into permanent law. The regulation requires that testing be performed again in 2020, and every five years thereafter.

Lead is a toxic metal that can be harmful to human health when ingested. Young children, especially those 6 years and younger, are at particular risk for lead exposure because they have frequent hand-to-mouth activity and absorb lead more easily than do adults. Children’s nervous systems are still undergoing development and thus are more susceptible to the effects of toxicants. Therefore, emphasis may be placed on assessment of lead exposure in schools and early childhood education facilities, where concentrations of a vulnerable population are regularly congregated.

Lead can be introduced into potable water by being present in the source water or, more commonly, by interaction of the water with fixtures and plumbing materials containing lead. Common sources of lead in potable water include solder, fluxes, pipes and pipe fittings, fixtures, and sediments. It is possible that different water outlets in a given building could have dissimilar concentrations of lead. It is also possible that, due to temporal fluctuations in water chemistry and physical conditions that may affect the integrity of the plumbing and the water being conveyed, the result obtained from a test at a given time may differ from the result obtained from a test at another time, even if the sampling procedures are identical.

## **II. PROJECT DESCRIPTION**

Due to COVID-19 restrictions imposed by New York State in March of 2020, sampling was delayed at Holley Central School District until the school was reopened in September of 2020. At that time, Holley Central School District adopted a “hybrid” teaching model which led to only partial capacity of student/teacher populations at their schools on a given day.

As part of this model, all fixtures are active in the schools excluding the drinking fountains, which are inaccessible to the students and faculty. After review of the state guidance sent out on October 13, 2020 extending the sampling deadline, and after discussion with LaBella representatives, the district decided to move forward with sampling all fixtures (including drinking fountains) during the month of October.

Holley Central School District maintenance members flushed each drinking fountain not currently in use the evening prior to sampling for approximately 30 seconds to 1 minute. This activity is part of a routine maintenance program the district has in place to flush fixtures approximately once per month. This was done to not only to remove water from the drinking fountains that had been over stagnated for several months, but to simulate regular usage during the day prior to sampling. It should be noted that students and faculty will continue to not have access to these fountains, as they were only opened to be flushed and sampled, and are locked at all other times while COVID-19



restrictions remain in place.

In accordance with sections 1370-a and 1110, Subpart 67-4 of Title 10 (Health) of the Official Compilation of Codes, Rules and Regulations of the State of New York and US EPA Guidelines, LaBella Associates performed sampling of potable water for lead contaminants for the Holley Central School District. Sampling was conducted on October 14, 2020 at the following buildings:

- Holley Middle School/High School – 16848 Lynch Road, Holley NY 14470

### III. SAMPLING PROCEDURES AND SUMMARY OF RESULTS

Plumbing drawings of the facility were reviewed, and LaBella Associates conducted a site walkthrough with district maintenance personnel to identify potable outlets required for testing. These outlets typically included drinking fountains, bottle fillers, restroom sinks, kitchen sinks, classroom sinks, bubblers, ice machines, and medical office sinks. Outlets categorically excluded from testing may include showers, janitor’s sinks, and mechanical room outlets. Typically, excluded outlets will be capable of being isolated by custodial staff, and will be accompanied by warning signs to prohibit consumption.

On the morning of October 14, 2020, LaBella staff conducted sampling of target outlets prior to facilities opening and before any water was used. The water conditions were reported to be representative of normal consumption patterns (given current occupancy rates) with building occupancy controlled during stagnation and sampling periods.

In accordance with Subpart 67-4 requirements sampling was limited to “first-draw” samples. A volume of the first 250 mL of water was taken from each cold water outlet in the inventory.

The samples were then promptly packaged and shipped to a NYS Department of Health Environmental Laboratory Approval Program (ELAP) accredited laboratory. Samples were analyzed utilizing EPA environmental analysis method 200.9 Rev 2.2 for lead in potable water. Results of the laboratory analyses, field testing and the visual on-site inspection were compiled and summarized.

<b>Holley Middle School/High School Sampling Summary for October 14, 2020</b>			
<b>Building</b>	<b>Total Number of Outlets</b>	<b>Total number of outlets at or below EPA action level (15ppb)</b>	<b>Total number of outlets above EPA action level (15ppb)</b>
Middle/High School	93	92	1

Based on laboratory analyses of the samples collected, the following outlets were determined to exceed the NYS Action level of 15 parts per billion (ppb) or equivalent 15 micrograms per liter ( $\mu\text{g/L}$ ). However, the following table does not include all of the outlets sampled during this inspection; for a full list of outlets sampled see Appendix A immediately following this report.



Holley Middle School/High School Samples Exceeding 15 ug/L (ppb) Reporting Threshold			
Sample Number	Sample Location	Outlet Type	Result (µg/L)
HHS-01-SP-BY-REC-T	Outside Spigot Near Receiving Dock	Spigot	16.4

*Special Note: Several fixtures did have a small amount of sample spilled, primarily due to the angle that the bottles needed to be filled, or the fixtures releasing water on a self-timer. Additionally, a select few fixtures were not sampled in the correct order. Given the volume of the water in the system, the amount of water drawn during sampling, and the amount of water spilled in certain instances, it is not believed that the validity of these samples are compromised.*

#### IV. Response and RECOMMENDATIONS

According to section Subpart 67-4.4 “Response” of the regulation, school districts shall prohibit the use of all outlets which exceed the 15 ppb action level. The outlet shall remain out of service until a lead remediation plan is implemented to reduce the level of lead and resampling indicates lead levels that at or below the action level. While the outlet is out of service the district must supply an appropriate amount of potable water for drinking or cooking to building occupants.

LaBella would provide the following recommendations for outlets in exceedance of the action level:

1. Follow up testing – This may include an additional first draw sample, or second draw sample to further investigate and evaluate the condition of the plumbing system upstream of the affected outlets. Sample results may provide some insight on trends, issues with certain portions of the plumbing system or links to specific outlets types and models.
2. Remedial Measures – The school district may elect to commence remediation of affected outlets with or without additional testing. Temporary remediation could include isolating outlets and providing alternate sources of potable drinking or cooking water. Permanent remediation could include replacing outlets, permanently isolating outlets, adding water filtration or renovations to the plumbing system.

#### V. Reporting and Record Keeping

In accordance with Subpart 67-4 the district shall:

- Report the test results to the local health department as soon as practicable, but no more than 1 business day after the school received the laboratory report.
- Notify all staff and all persons in parental relation to children or students of the test results, in writing, as soon as practicable but no more than 10 business days after the school received the laboratory report.
- The school shall make available, on the school’s website, the results of all lead testing



performed and lead remediation plans implemented pursuant to this Subpart, as soon as practicable, but no more than 6 weeks after the school received the laboratory reports.

- As soon as practicable, but no more than 10 business days after the school received the laboratory reports, the school shall report data relating to test results to the Department, local health department, and State Education Department, through the Department's designated statewide electronic reporting system.
- The school shall retain all records of test results, lead remediation plans, determinations that a building is lead-free, and waiver requests, for ten years following the creation of such documentation. Copies of such documentation shall be immediately provided to the Department, local health department, or State Education Department, upon request.

# **Appendix A**

## **Detailed Results Spreadsheet**

<b>Holley Middle/High School Lead Results By Fixture - October 14, 2020</b>			
<b>Sample ID</b>	<b>Description</b>	<b>Time Sampled</b>	<b>Lead Level (ug/L)</b>
HHS-01-SP-BY-REC-T	Outside Spigot Near Receiving Dock	530	16.4
HHS-01-BT-IN-REC-T	Receiving Dock Bathroom Sink	603	<5.0
HHS-01-KI-BY-904-T1	Kitchen Outlet #1 (Clockwise Around Room)	531	<5.0
HHS-01-KI-BY-904-T2	Kitchen Outlet #2 (Clockwise Around Room)	532	<10.0
HHS-01-KI-BY-904-T3	Kitchen Outlet #3 (Clockwise Around Room)	533	<5.0
HHS-01-KI-BY-904-IM	Kitchen Outlet Ice Machine (Clockwise Around Room)	534	<5.0
HHS-01-SA-IN-902-T1	Cafeteria Serving Area Sink #1	541	<5.0
HHS-01-KI-BY-904-T5	Kitchen Outlet #5 (Clockwise Around Room)	542	<5.0
HHS-01-KI-BY-904-T4	Kitchen Outlet #4 (Clockwise Around Room)	544	<5.0
HHS-01-SA-IN-902-T2	Cafeteria Serving Area Sink #2	550	<5.0
HHS-01-BT-BY-905-T	Restroom by Room 905	530	<5.0
HHS-01-FAC-IN-901-T	Faculty Cafeteria Lounge Sink (Room 901)	607	<5.0
HHS-01-DW-BY-902-T2	Right Hand Side Dishwashing Tap (near 902)	610	<5.0
HHS-01-DW-BY-902-T1	Left Hand Side Dishwashing Tap (near 902)	610	<5.0
HHS-01-DW-BY-902-T3	Singular Dishwashing Fixture (near 902)	610	<5.0
HHS-01-HA-BY-900-DF1	Left Hand Drinking Fountain Near Cafeteria	617	<5.0
HHS-01-HA-BY-900-DF2	Right Hand Drinking Fountain Near Cafeteria	617	<5.0



HHS-01-BT-BY-900-T	Men's Restroom Sink Across From Cafeteria	619	<5.0
HHS-01-GT-BY-900-T	Women's Restroom Sink Across From Cafeteria	619	<5.0
HHS-01-HA-IN-012-DF	Drinking Fountain Near Room 012	621	<5.0
HHS-01-BT-IN-806A-T	Men's Phys. Ed. Teacher Office Sink	622	<5.0
HHS-01-HA-IN-807-DF	Drinking Fountain In Boy's Locker Room Hall	623	<5.0
HHS-01-BT-BY-807-T	Boy's Locker Room Restroom	624	<5.0
HHS-01-HA-BY-026-DF	Drinking Fountain Near Room 026	627	<5.0
HHS-01-HA-BY-026-BF	Bottle Filler Near Room 026	627	<5.0
HHS-01-BT-IN-026-T2	Boys Restroom (Room 026) Middle Tap	629	<5.0
HHS-01-BT-IN-026-T3	Boys Restroom (Room 026) Right Tap	629	<5.0
HHS-01-HA-BY-027-DF	Drinking Fountain Near Room 027	630	<5.0
HHS-01-GT-IN-027-T1	Girls Restroom (Room 027) Left Tap	631	<5.0
HHS-01-GT-IN-027-T2	Girls Restroom (Room 027) Middle Left Tap	631	<5.0
HHS-01-GT-IN-027-T3	Girls Restroom (Room 027) Middle Right Tap	631	<5.0
HHS-01-GT-IN-027-T4	Girls Restroom (Room 027) Right Tap	631	<5.0
HHS-01-GT-IN-801A-T	Girl's Phys. Ed. Teacher Office Sink	634	<5.0
HHS-01-HA-IN-802-DF	Drinking Fountain In Girl's Locker Room Hall	636	<5.0
HHS-01-GT-BY-802-T	Girl's Locker Room Restroom	636	<5.0
HHS-01-NO-IN-100C-T	Nurse's Exam Room Sink	639	<5.0
HHS-01-BT-IN-100A-T	Nurse's Restroom Sink	639	<5.0
HHS-01-RM-IN-506D-T	Sink In Room 506D (Library Office)	642	<5.0
HHS-01-BT-IN-511-T	Sink in Bathroom Nearest to the Library (Room 511)	642	<5.0
HHS-01-BT-IN-510-T	Sink in Bathroom Closest to the Mail Room (Room 510)	644	<5.0

HHS-01-FAC-BY-504-T	Faculty Room Sink Near Room 504	645	<5.0
HHS-01-BT-IN-025-T1	Faculty Men's Restroom (Room 025) Left Sink	646	10.5
HHS-01-BT-IN-025-T2	Faculty Men's Restroom (Room 025) Right Sink	646	<5.0
HHS-01-GT-IN-024-T1	Faculty Women's Restroom (Room 024) Left Sink	647	<5.0
HHS-01-GT-IN-024-T2	Faculty Women's Restroom (Room 024) Right Sink	647	<5.0
HHS-01-GT-IN-023-T3	Girl's Restroom (Room 023) Right Sink	648	<5.0
HHS-01-GT-IN-023-T1	Girl's Restroom (Room 023) Left Sink	648	<5.0
HHS-01-BT-IN-022-T3	Boy's Restroom (Room 022) Right Sink	650	<5.0
HHS-01-BT-IN-022-T2	Boy's Restroom (Room 022) Middle Sink	650	<5.0
HHS-01-BT-IN-022-T1	Boy's Restroom (Room 022) Left Sink	650	<5.0
HHS-01-BT-IN-021-T3	Boy's Restroom (021) Right Sink	652	<5.0
HHS-01-BT-IN-021-T2	Boy's Restroom (021) Middle Sink	652	<5.0
HHS-01-BT-IN-021-T1	Boy's Restroom (021) Left Sink	652	<5.0
HHS-01-GT-IN-020-T3	Girl's Restroom (Room 020) Right Sink	654	<5.0
HHS-01-GT-IN-020-T2	Girl's Restroom (Room 020) Middle Sink	654	<5.0
HHS-01-RM-IN-402-T3	Room 402 Right Sink	656	<5.0
HHS-01-RM-IN-402-T2	Room 402 Middle Sink	656	<5.0
HHS-01-RM-IN-402-T1	Room 402 Left Sink	656	<5.0
HHS-01-HA-BY-402-DF2	Right Drinking Fountain Near Room 402	658	<5.0
HHS-01-HA-BY-402-DF1	Left Drinking Fountain Near Room 402	658	<5.0
HHS-01-RM-IN-211-T6	Science Room 211 Sink #6	700	<5.0
HHS-01-RM-IN-211-T5	Science Room 211 Sink #5	700	<5.0
HHS-01-RM-IN-211-T4	Science Room 211 Sink #4	700	<5.0

HHS-01-RM-IN-211-T3	Science Room 211 Sink #3	700	<5.0
HHS-01-RM-IN-211-T1	Science Room 211 Sink #1	700	<5.0
HHS-01-RM-IN-212-T	Room 212 Sink	704	<5.0
HHS-01-RM-IN-214-T4	Room 214 Sink #4	705	<5.0
HHS-01-RM-IN-214-T3	Room 214 Sink #3	705	<5.0
HHS-01-RM-IN-214-T2	Room 214 Sink #2	705	<5.0
HHS-01-RM-IN-214-T1	Room 214 Sink #1	705	<5.0
HHS-01-RM-IN-304-T2	Room 304 Right Sink	707	<5.0
HHS-01-RM-IN-304-T1	Room 304 Left Sink	707	<5.0
HHS-01-RM-IN-306-T2	Room 306 Right Sink	709	<5.0
HHS-01-RM-IN-306-T1	Room 306 Left Sink	709	<5.0
HHS-01-HA-BY-107-DF1	Hallway Left Side Drinking Fountain (by Room 107)	711	8.36
HHS-01-HA-BY-107-DF2	Hallway Right Side Drinking Fountain (by Room 107)	711	<5.0
HHS-01-HA-BY-107-BF	Hallway Bottle Filler (by Room 107)	711	<5.0
HHS-01-RM-IN-110A-T	Sink in Room 110A	713	6.42
HHS-01-RM-IN-110-T1	Room 110 Sink #1	714	<5.0
HHS-01-RM-IN-110-T2	Room 110 Sink #2	714	<5.0
HHS-01-RM-IN-110-T3	Room 110 Sink #3	714	<5.0
HHS-01-RM-IN-110-T4	Room 110 Sink #4	714	<5.0
HHS-01-RM-IN-110-T5	Room 110 Sink #5	714	<5.0
HHS-01-RM-IN-109A-T	Sink in Room 109A	717	<5.0
HHS-01-RM-IN-109-T4	Room 109 Sink #4	719	<5.0
HHS-01-RM-IN-109-T3	Room 109 Sink #3	719	<5.0
HHS-01-RM-IN-109-T2	Room 109 Sink #2	719	<5.0
HHS-01-RM-IN-109-T1	Room 109 Sink #1	719	<5.0
HHS-01-RM-IN-108-T1	Room 108 Sink #1	721	<5.0
HHS-01-RM-IN-108-T2	Room 108 Sink #2	721	<5.0
HHS-01-RM-IN-108-T3	Room 108 Sink #3	721	<5.0
HHS-01-RM-IN-108-T4	Room 108 Sink #4	721	<5.0

HHS-01-RM-IN-108-T5	Room 108 Sink #5	721	<5.0
---------------------	------------------	-----	------

# **Appendix B**

## Laboratory Analytical Results



Analysis Report

Schneider Laboratories Global, Inc

2512 W. Cary Street • Richmond, Virginia • 23220-5117
804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

Customer: Labella Associates (1126)
Address: 300 State Street
Rochester, NY 14614-1098

Order #: 390678

Matrix: Drinking Water
Received: 10/19/20
Reported: 10/22/20

Attn:
Project: Holley Middle/High School LIDW
Location: 16848 Lynch Rd Holley NY 14470
Number: 2202182

PO Number:

Table with columns: Sample ID, Cust. Sample ID, Location, Parameter, Method, Result, RL\*, Units, Analysis Date, Analyst. Contains 10 rows of metal analysis data for Lead, including sample IDs like 390678-001 and 390678-010.

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and \*Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.



Customer: Labella Associates (1126)  
Address: 300 State Street  
Rochester, NY 14614-1098

Order #: 390678

Matrix: Drinking Water  
Received: 10/19/20  
Reported: 10/22/20

Attn:  
Project: Holley Middle/High School LIDW  
Location: 16848 Lynch Rd Holley NY 14470  
Number: 2202182

PO Number:

Sample ID	Cust. Sample ID	Location	Result	RL*	Units	Analysis Date	Analyst
Parameter		Method					
390678-011	BT-IN-REC-T	Rec Dock Bathrm Sink					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	10/20/20	MY
390678-012	FAC-IN-901-T	Faculty Cafeteria Lounge					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	10/20/20	MY
390678-013	DW-BY-902-T2	Right Dishwashing Tap					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	10/20/20	MY
390678-014	DW-BY-902-T1	Left Dishwashing Tap					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	10/20/20	MY
390678-015	DW-BY-902-T3	Singular Dishwashing Fixt					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	10/20/20	MY
390678-016	HA-BY-900-DF1	Left DF Near Cafeteria					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	10/20/20	MY
390678-017	HA-BY-900-DF2	Right DF Near Cafeteria					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	10/20/20	MY
390678-018	BT-BY-900-T	Men's Restrmm Across					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	10/20/20	MY
390678-019	GT-BY-900-T	Women's Restrmm Across					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	10/20/20	MY
390678-020	HA-IN-012-DF	Drinking Fount Near 012					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	10/20/20	MY
390678-021	BT-IN-806A-T	Men's Phys Ed Office Sink					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	10/20/20	MY

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and \*Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.



Customer: Labella Associates (1126)  
Address: 300 State Street  
Rochester, NY 14614-1098

Order #: 390678

Matrix: Drinking Water  
Received: 10/19/20  
Reported: 10/22/20

Attn:  
Project: Holley Middle/High School LIDW  
Location: 16848 Lynch Rd Holley NY 14470  
Number: 2202182

PO Number:

Sample ID	Cust. Sample ID	Location	Result	RL*	Units	Analysis Date	Analyst
Parameter		Method					
<b>390678-022</b>	HA-IN-807-DF	DF in Boy's Locker Rm					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	10/21/20	MY
<b>390678-023</b>	BT-BY-807-T	Boys Locker Rm Restr					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	10/21/20	MY
<b>390678-024</b>	HA-BY-026-DF	DF Near Rm 026					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	10/21/20	MY
<b>390678-025</b>	HA-BY-026-BF	BF Near Rm 026					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	10/21/20	MY
<b>390678-027</b>	BT-IN-026-T2	Boys Restr					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	10/21/20	MY
<b>390678-028</b>	BT-IN-026-T3	Boys Restr Right Tap					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	10/21/20	MY
<b>390678-029</b>	HA-BY-027-DF	DF Near Room 027					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	10/21/20	MY
<b>390678-030</b>	GT-IN-027-T1	Girls Restr Left Tap					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	10/21/20	MY
<b>390678-031</b>	GT-IN-027-T2	Girls Restr Middle Left					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	10/21/20	MY
<b>390678-032</b>	GT-IN-027-T3	Girls Restr Middle Right					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	10/21/20	MY
<b>390678-033</b>	GT-IN-027-T4	Girls Restr Right Tap					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	10/21/20	MY

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and \*Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.





Customer: Labella Associates (1126)  
Address: 300 State Street  
Rochester, NY 14614-1098

Order #: 390678

Matrix: Drinking Water  
Received: 10/19/20  
Reported: 10/22/20

Attn:  
Project: Holley Middle/High School LIDW  
Location: 16848 Lynch Rd Holley NY 14470  
Number: 2202182

PO Number:

Sample ID	Cust. Sample ID	Location	Result	RL*	Units	Analysis Date	Analyst
Parameter		Method					
<b>390678-034</b>	GT-IN-801A-T	Girls Phys Ed Office Sink					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	10/21/20	MY
<b>390678-035</b>	HA-IN-802-DF	DF in Girls Locker Rm					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	10/21/20	MY
<b>390678-036</b>	GT-BY-802-T	Girls Locker Rm Restr					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	10/21/20	MY
<b>390678-037</b>	NO-IN-100C-T	Nurse's Exam Room Sink					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	10/21/20	MY
<b>390678-038</b>	BT-IN-100A-T	Nurse's Restr					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	10/21/20	MY
<b>390678-039</b>	RM-IN-506D-T	Sink in Library Office					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	10/21/20	MY
<b>390678-040</b>	BT-IN-511-T	Sink in Bath Near Library					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	10/21/20	MY
<b>390678-041</b>	BT-IN-510-T	Sink in Bath Near Mail Rm					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	10/21/20	MY
<b>390678-042</b>	FAC-BY-504-T	Faculty Rm Sink Near 504					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	10/21/20	MY
<b>390678-043</b>	BT-IN-025-T1	Faculty Mens Rm Left Sink					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	10.5	5.00	µg/L	10/22/20	SA
<b>390678-044</b>	BT-IN-025-T2	Faculty Mens Rm Right					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	10/22/20	SA

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and \*Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.



Customer: Labella Associates (1126)  
Address: 300 State Street  
Rochester, NY 14614-1098

Order #: 390678

Matrix: Drinking Water  
Received: 10/19/20  
Reported: 10/22/20

Attn:  
Project: Holley Middle/High School LIDW  
Location: 16848 Lynch Rd Holley NY 14470  
Number: 2202182

PO Number:

Sample ID	Cust. Sample ID	Location	Result	RL*	Units	Analysis Date	Analyst
Parameter		Method					
<b>390678-045</b>	GT-IN-024-T1	Faculty Womens Rm Left					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	10/22/20	SA
<b>390678-046</b>	GT-IN-024-T2	Faculty Womens Rm Right					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	10/22/20	SA
<b>390678-047</b>	GT-IN-023-T3	Girls Restrm Right Sink					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	10/22/20	SA
<b>390678-049</b>	GT-IN-023-T1	Girls Restrm Left Sink					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	10/22/20	SA
<b>390678-050</b>	BT-IN-022-T3	Boys Restrm Right Sink					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	10/22/20	SA
<b>390678-051</b>	BT-IN-022-T2	Boys Restrm Middle Sink					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	10/20/20	MY
<b>390678-052</b>	BT-IN-022-T1	Boys Restrm Left Sink					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	10/20/20	MY
<b>390678-053</b>	BT-IN-021-T3	Boys Restrm Right Sink					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	10/20/20	MY
<b>390678-054</b>	BT-IN-021-T2	Boys Restrm Middle Sink					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	10/20/20	MY
<b>390678-055</b>	BT-IN-021-T1	Boys Restrm Left Sink					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	10/20/20	MY
<b>390678-056</b>	GT-IN-020-T3	Girls Restrm Right Sink					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	10/20/20	MY

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and \*Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.



Analysis Report

Schneider Laboratories Global, Inc

2512 W. Cary Street • Richmond, Virginia • 23220-5117
804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

Customer: Labella Associates (1126)
Address: 300 State Street
Rochester, NY 14614-1098

Order #: 390678

Matrix: Drinking Water
Received: 10/19/20
Reported: 10/22/20

Attn:
Project: Holley Middle/High School LIDW
Location: 16848 Lynch Rd Holley NY 14470
Number: 2202182

PO Number:

Table with columns: Sample ID, Cust. Sample ID, Location, Method, Result, RL\*, Units, Analysis Date, Analyst. Contains multiple rows for 'Metals Analysis' (Lead) across various sample IDs and locations.

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and \*Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.



Analysis Report

Schneider Laboratories Global, Inc

2512 W. Cary Street • Richmond, Virginia • 23220-5117
804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

Customer: Labella Associates (1126)
Address: 300 State Street
Rochester, NY 14614-1098

Order #: 390678

Matrix: Drinking Water
Received: 10/19/20
Reported: 10/22/20

Attn:
Project: Holley Middle/High School LIDW
Location: 16848 Lynch Rd Holley NY 14470
Number: 2202182

PO Number:

Table with columns: Sample ID, Cust. Sample ID, Location, Parameter, Method, Result, RL\*, Units, Analysis Date, Analyst. Rows include sample IDs 390678-070 through 390678-080, all showing Lead analysis results.

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and \*Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.



Analysis Report

Schneider Laboratories Global, Inc

2512 W. Cary Street • Richmond, Virginia • 23220-5117
804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

Customer: Labella Associates (1126)
Address: 300 State Street
Rochester, NY 14614-1098

Order #: 390678

Matrix: Drinking Water
Received: 10/19/20
Reported: 10/22/20

Attn:
Project: Holley Middle/High School LIDW
Location: 16848 Lynch Rd Holley NY 14470
Number: 2202182

PO Number:

Table with columns: Sample ID, Cust. Sample ID, Location, Method, Result, RL\*, Units, Analysis Date, Analyst. Rows include sample IDs 390678-081 through 390678-091, all showing Lead results <5.00.

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and \*Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.



Analysis Report

Schneider Laboratories Global, Inc

2512 W. Cary Street • Richmond, Virginia • 23220-5117
804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

Customer: Labella Associates (1126)
Address: 300 State Street
Rochester, NY 14614-1098

Order #: 390678

Matrix: Drinking Water
Received: 10/19/20
Reported: 10/22/20

Attn:
Project: Holley Middle/High School LIDW
Location: 16848 Lynch Rd Holley NY 14470
Number: 2202182

PO Number:

Table with 8 columns: Sample ID, Cust. Sample ID, Location, Method, Result, RL\*, Units, Analysis Date, Analyst. Contains 7 rows of Metals Analysis data for Lead, all with results <5.00.

390678-10/22/20 04:37 PM

Handwritten signature of Jennifer Lee

Reviewed By: Jennifer Lee
Manager

EPA Regulatory Limits

Table with 3 columns: Parameter, Reg. Limit, Unit. Row 1: Lead, 15.0, µg/L

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and \*Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.



Analysis Report

Schneider Laboratories Global, Inc

2512 W. Cary Street • Richmond, Virginia • 23220-5117
804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

Customer: Labella Associates (1126)
Address: 300 State Street
Rochester, NY 14614-1098

Order #: 390678

Matrix: Drinking Water
Received: 10/19/20
Reported: 10/22/20

Attn:
Project: Holley Middle/High School LIDW
Location: 16848 Lynch Rd Holley NY 14470
Number: 2202182

PO Number:

Table with 8 columns: Sample ID, Cust. Sample ID, Location, Parameter, Method, Result, RL\*, Units, Analysis Date, Analyst

State Certifications

Table with 4 columns: Method, Parameter, New York, Virginia

Table with 2 columns: State, Certificate Number

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and \*Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.



# SCHNEIDER LABORATORIES GLOBAL, INC.

2512 West Cary Street, Richmond, Virginia 23220-5117  
804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475  
www.slabinc.com e-mail: info@slabinc.com

S 97

## 390678

V:\390\390678

abruner 10/19/2020 9:33:00 AM  
UPS 1Z153E79035706589

Submitting Co. <b>LaBella Associates, D.P.C.</b>	Lab WO#	Phone
<b>300 State Street</b>	Acct # <b>1126</b>	Fax / Email <b>dburgess@labellapc.com</b>
<b>Rochester, New York 14614</b>	**State of Collection <b>NY</b>	**Cert. Required <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
Project Name: <b>Holley Middle/High School LIDW Sampling</b>	Special Instructions [include requests for special reporting or data packages]	
Project Location: <b>16848 Lynch Road, Holley, NY 14470</b>	Page 1 of 5	
Project Number: <b>2202182</b>		
PO Number:		

Turn Around Time	Matrix / Sample Type (Select ONE)	Tests / Analytes (Select ALL that Apply)		
<input type="checkbox"/> 2 hours* <input type="checkbox"/> Same day* <input type="checkbox"/> 1 business day* <input type="checkbox"/> 2 business day* <input type="checkbox"/> 3 business days* <input checked="" type="checkbox"/> 5 business days* <input type="checkbox"/> Full TCLP (10d) <input type="checkbox"/> Weekend* <small>* not available for all tests</small> <small>Schedule rush organics, multi-metals &amp; weekend tests in advance.</small>	<small>All samples on form should be of SAME matrix type. Use additional forms as needed.</small> <input type="checkbox"/> Air <input type="checkbox"/> Solid <input type="checkbox"/> Aqueous <input type="checkbox"/> Waste <input type="checkbox"/> Bulk <input type="checkbox"/> Wastewater <input type="checkbox"/> Hi-Vol Filter (PM10) <input type="checkbox"/> Water, Drinking <input type="checkbox"/> Hi-Vol Filter (TSP) <input type="checkbox"/> Compliance <input type="checkbox"/> Oil <input type="checkbox"/> Wipe <input type="checkbox"/> Paint <input type="checkbox"/> Wipe, Composite <input type="checkbox"/> Sludge <input type="checkbox"/> _____ <input type="checkbox"/> Soil <input type="checkbox"/> _____	<b>Asbestos Air / Fiber Counts</b> <input type="checkbox"/> PCM (NIOSH 7400) <input type="checkbox"/> TEM (AHERA) <input type="checkbox"/> TEM (EPA Level II) <input type="checkbox"/> _____ <b>Miscellaneous Tests</b> <input type="checkbox"/> Total Dust (NIOSH 0500) <input type="checkbox"/> Resp. Dust (NIOSH 0600) <input type="checkbox"/> Silica - FTIR (NIOSH 7602) <input type="checkbox"/> Silica - XRD (NIOSH 7500) <input type="checkbox"/> Mold Direct Exam	<b>Asbestos Bulk / Asb ID</b> <input type="checkbox"/> PLM (EPA 600/R-93/116) <input type="checkbox"/> PLM (EPA Point Count) <input type="checkbox"/> PLM (Qualitative only) <input type="checkbox"/> NYELAP 198.11.4/.6 <input type="checkbox"/> CAELAP (EPA Interim) <input type="checkbox"/> TEM (Chatfield) <input type="checkbox"/> _____ <b>FOR ASBESTOS AIR:</b> TYPE OF RESPIRATOR USED: _____	<b>Metals-Total Conc.</b> <input checked="" type="checkbox"/> Lead <input type="checkbox"/> RCRA Metals <input type="checkbox"/> _____ <input type="checkbox"/> _____ <b>Metals-Extract</b> <input type="checkbox"/> TCLP / Lead <input type="checkbox"/> TCLP / RCRA Metals <input type="checkbox"/> TCLP / Full (w/ organics) <b>Others</b> <input type="checkbox"/> _____

Sample #	Date Sampled**	Time Sampled**	Sample Identification (Employee, SSN, Bldg, Material, Type <sup>1</sup> )	Wiped Area (ft <sup>2</sup> )	pH / Temp *	Time <sup>2</sup>		Flow Rate <sup>3</sup>		Total <sup>4</sup> Air
						Start	Stop	Start	Stop	
SP-BY-REC-T	10/14/20	0530	Outside Spigot Near Receiving Dock							
BT-BY-905-T	10/14/20	0530	Restroom by Room 905							
KI-BY-904-T1	10/14/20	0531	Kitchen Outlet #1							
KI-BY-904-T2	10/14/20	0532	Kitchen Outlet #2							
KI-BY-904-T3	10/14/20	0533	Kitchen Outlet #3							
KI-BY-904-IM	10/14/20	0534	Kitchen Ice Machine							
SA-IN-902-T1	10/14/20	0541	Cafeteria Serving Area Sink #1							
KI-BY-904-T5	10/14/20	0542	Kitchen Outlet #5							
KI-BY-904-T4	10/14/20	0544	Kitchen Outlet #4							
SA-IN-902-T2	10/14/20	0550	Cafeteria Serving Area Sink #2							
BT-IN-REC-T	10/14/20	0603	Receiving Dock Bathroom Sink							
FAC-IN-901-T	10/14/20	0607	Faculty Cafeteria Lounge Sink							

<sup>1</sup>Type: A=area B=blank P=personal E=excursion <sup>2</sup>Beginning/End of Sample Period <sup>3</sup>Pump Calibration in Liters/Minute <sup>4</sup>Volume in Liters [time in min \* flow in L/min]

<b>Sampled by</b> NAME <u>Cory Stamp</u> SIGNATURE _____ DATE/TIME <u>10/14/20 0730</u>	<b>Relinquished to lab by</b> NAME <u>Cory Stamp</u> SIGNATURE _____ DATE/TIME <u>10/14/20 1300</u>	<b>Sample Disposal</b> <small>if samples over req. weight (Refer to Fee Schedule)</small> <input type="checkbox"/> Return to Sender (Shipping fees) <input type="checkbox"/> Disposal by lab (\$50 fee) <b>Shipping Methods</b> <input type="checkbox"/> FX <input type="checkbox"/> UPS <input type="checkbox"/> USM <input type="checkbox"/> HD <input type="checkbox"/> DB WB: _____
--	--	--

Sample return requested  Ambient temp  Ice  Cl  R  S  X  Receive a physical copy of report.

\* Temperature taken with IR Gun A. \*\*Required.

Chain-of-Custody documentation continued internally within lab. Terms and conditions page 2.



Additional Pages of the Chain of Custody are only necessary if needed for additional sample information

Sample #	Sample Description	Date Sampled	Time Sampled
DW-BY-902-T2	Right Dishwashing Tap	10/14/2020	0610
DW-BY-902-T1	Left Dishwashing Tap	10/14/2020	0610
DW-BY-902-T3	Singular Dishwashing Fixture	10/14/2020	0610
HA-BY-900-DF1	Left DF Near Cafeteria	10/14/2020	0617
HA-BY-900-DF2	Right DF Near Cafeteria	10/14/2020	0617
BT-BY-900-T	Men's Restroom Across Cafeteria	10/14/2020	0619
GT-BY-900-T	Women's Restroom Across Cafeteria	10/14/2020	0619
HA-IN-012-DF	Drinking Fountain Near 012	10/14/2020	0621
BT-IN-806A-T	Men's Phys Ed Office Sink	10/14/2020	0622
HA-IN-807-DF	DF in Boy's Locker Room Hall	10/14/2020	0623
BT-BY-807-T	Boy's Locker Room Restroom	10/14/2020	0624
HA-BY-026-DF	DF Near Room 026	10/14/2020	0627
HA-BY-026-BF	BF Near Room 026	10/14/2020	0627
BT-IN-026-T1	Boy's Restroom Left Tap	10/14/2020	0629
BT-IN-026-T2	Boy's Restroom Middle Tap	10/14/2020	0629
BT-IN-026-T3	Boy's Restroom Right Tap	10/14/2020	0629
HA-BY-027-DF	DF Near Room 027	10/14/2020	0630
GT-IN-027-T1	Girl's Restroom Left Tap	10/14/2020	0631
GT-IN-027-T2	Girl's Restroom Middle Left Tap	10/14/2020	0631
GT-IN-027-T3	Girl's Restroom Middle Right Tap	10/14/2020	0631
GT-IN-027-T4	Girl's Restroom Right Tap	10/14/2020	0631
GT-IN-801A-T	Girl's Phys Ed Office Sink	10/14/2020	0634
HA-IN-802-DF	DF in Girl's Locker Rm Hall	10/14/2020	0636
<b>*Comments/Special Instructions:</b>			

Additional Pages of the Chain of Custody are only necessary if needed for additional sample information

Sample #	Sample Description	Date Sampled	Time Sampled
GT-BY-802-T	Girl's Locker Room Restroom	10/14/2020	0636
NO-IN-100C-T	Nurse's Exam Room Sink	10/14/2020	0639
BT-IN-100A-T	Nurse's Restroom Sink	10/14/2020	0639
RM-IN-506D-T	Sink in Library Office	10/14/2020	0642
BT-IN-511-T	Sink in Bath. Near Library	10/14/2020	0642
BT-IN-510-T	Sink in Bath. Near Mail Room	10/14/2020	0644
FAC-BY-504-T	Faculty Room Sink Near 504	10/14/2020	0645
BT-IN-025-T1	Faculty Men's Room Left Sink	10/14/2020	0646
BT-IN-025-T2	Faculty Men's Room Right Sink	10/14/2020	0646
GT-IN-024-T1	Faculty Women's Room Left Sink	10/14/2020	0647
GT-IN-024-T2	Faculty Women's Room Right Sink	10/14/2020	0647
GT-IN-023-T3	Girl's Restroom Right Sink	10/14/2020	0648
GT-IN-023-T2	Girl's Restroom Middle Sink	10/14/2020	0648
GT-IN-023-T1	Girl's Restroom Left Sink	10/14/2020	0648
BT-IN-022-T3	Boy's Restroom Right Sink	10/14/2020	0650
BT-IN-022-T2	Boy's Restroom Middle Sink	10/14/2020	0650
BT-IN-022-T1	Boy's Restroom Left Sink	10/14/2020	0650
BT-IN-021-T3	Boy's Restroom Right Sink	10/14/2020	0652
BT-IN-021-T2	Boy's Restroom Middle Sink	10/14/2020	0652
BT-IN-021-T1	Boy's Restroom Left Sink	10/14/2020	0652
GT-IN-020-T3	Girl's Restroom Right Sink	10/14/2020	0654
GT-IN-020-T2	Girl's Restroom Middle Sink	10/14/2020	0654
GT-IN-020-T1	Girl's Restroom Left Sink	10/14/2020	0654

\*Comments/Special Instructions:

Additional Pages of the Chain of Custody are only necessary if needed for additional sample information

Sample #	Sample Description	Date Sampled	Time Sampled
RM-IN-402-T3	Room 402 Right Sink	10/14/2020	0656
RM-IN-402-T2	Room 402 Middle Sink	10/14/2020	0656
RM-IN-402-T1	Room 402 Left Sink	10/14/2020	0656
HA-BY-402-DF2	Right DF Near Room 402	10/14/2020	0658
HA-BY-402-DF1	Left DF Near Room 402	10/14/2020	0658
RM-IN-211-T6	Science Room 211 Sink 6	10/14/2020	0700
RM-IN-211-T5	Science Room 211 Sink 5	10/14/2020	0700
RM-IN-211-T4	Science Room 211 Sink 4	10/14/2020	0700
RM-IN-211-T3	Science Room 211 Sink 3	10/14/2020	0700
RM-IN-211-T2	Science Room 211 Sink 2	10/14/2020	0700
RM-IN-211-T1	Science Room 211 Sink 1	10/14/2020	0700
RM-IN-212-T	Science Room 212 Sink	10/14/2020	0704
RM-IN-214-T4	Room 214 Sink 4	10/14/2020	0705
RM-IN-214-T3	Room 214 Sink 3	10/14/2020	0705
RM-IN-214-T2	Room 214 Sink 2	10/14/2020	0705
RM-IN-214-T1	Room 214 Sink 1	10/14/2020	0705
RM-IN-304-T2	Room 304 Right Sink	10/14/2020	0707
RM-IN-304-T1	Room 304 Left Sink	10/14/2020	0707
RM-IN-306-T2	Room 306 Right Sink	10/14/2020	0709
RM-IN-306-T1	Room 306 Left Sink	10/14/2020	0709
HA-BY-107-DF1	Left DF Near 107	10/14/2020	0711
HA-BY-107-DF2	Right DF Near 107	10/14/2020	0711
HA-BY-107-BF	Bottle Filler Near 107	10/14/2020	0711
<b>*Comments/Special Instructions:</b>			

Additional Pages of the Chain of Custody are only necessary if needed for additional sample information

Sample #	Sample Description	Date Sampled	Time Sampled
RM-IN-110A-T	Sink in Room 110A	10/14/2020	0713
RM-IN-110-T1	Room 110 Sink 1	10/14/2020	0714
RM-IN-110-T2	Room 110 Sink 2	10/14/2020	0714
RM-IN-110-T3	Room 110 Sink 3	10/14/2020	0714
RM-IN-110-T4	Room 110 Sink 4	10/14/2020	0714
RM-IN-110-T5	Room 110 Sink 5	10/14/2020	0714
RM-IN-109A-T	Room 109A Sink	10/14/2020	0717
RM-IN-109-T4	Room 109 Sink 4	10/14/2020	0719
RM-IN-109-T3	Room 109 Sink 3	10/14/2020	0719
RM-IN-109-T2	Room 109 Sink 2	10/14/2020	0719
RM-IN-109-T1	Room 109 Sink 1	10/14/2020	0719
RM-IN-108-T1	Room 108 Sink 1	10/14/2020	0721
RM-IN-108-T2	Room 108 Sink 2	10/14/2020	0721
RM-IN-108-T3	Room 108 Sink 3	10/14/2020	0721
RM-IN-108-T4	Room 108 Sink 4	10/14/2020	0721
RM-IN-108-T5	Room 108 Sink 5	10/14/2020	0721

\*Comments/Special Instructions:

# **Appendix C**

## Laboratory Certification

NEW YORK STATE DEPARTMENT OF HEALTH  
WADSWORTH CENTER



Expires 12:01 AM April 01, 2021  
Issued April 01, 2020

**CERTIFICATE OF APPROVAL FOR LABORATORY SERVICE**

*Issued in accordance with and pursuant to section 502 Public Health Law of New York State*

MR. FAYEZ ABOUZAKI  
SCHNEIDER LABORATORIES GLOBAL, INC  
2512 WEST CARY STREET  
RICHMOND, VA 23220-5117

NY Lab Id No: 11413

*is hereby APPROVED as an Environmental Laboratory in conformance with the  
National Environmental Laboratory Accreditation Conference Standards (2003) for the category  
ENVIRONMENTAL ANALYSES POTABLE WATER  
All approved analytes are listed below:*

**Metals I**

Lead, Total

EPA 200.9 Rev. 2.2



Serial No.: 61370

Property of the New York State Department of Health. Certificates are valid only at the address shown, must be conspicuously posted, and are printed on secure paper. Continued accreditation depends on successful ongoing participation in the Program. Consumers are urged to call (518) 485-5570 to verify the laboratory's accreditation status.

