

November 29, 2016

Mr. John Sherman
Holley Central School District
3800 North Main Street
Holley, New York 14470

Re: Environmental Water Sampling – Holley CSD Transportation Center

Dear Mr. Sherman,

Envoy Environmental was contracted on September 20, 2016 to perform Environmental Water Sampling at the Holley CSD Transportation Center located at 3800 North Main Street in Holley, New York. We understand the Holley Central School District is evaluating the data based on the NYS Department of Health (“NYSDOH”) Emergency Regulation, Lead Testing in School Drinking Water (Subpart 67-4) as well as the EPA’s 3T’s for Reducing Lead in Drinking Water in Schools Guidance Document. All sampling conducted was done in accordance with the NYSDOH regulations as it pertains to testing schools for lead in the drinking water.

Samples taken were based on both the direction of the client, and areas designated as high priority as outlined by the NYSDOH regulations. All water samples collected were 250 mL and taken as a “first draw” from each testing location. First draw samples are defined as a sample of tap water, collected in accordance with the NYSDOH regulations, that has been standing in plumbing pipes at least 8 hours and not more than 18 hours and is collected without prior flushing of the tap. The NYSDOH regulations identifies the Action Level at 15 ppb.

Water sampling analysis was contracted through EHS, LLC located in Richmond, Virginia, a NYS ELAP approved laboratory. The sampling and analytical testing was conducted in compliance with the USEPA Requirements for Lead Sampling and Testing Protocols. The following USEPA Methodologies were used to prepare and analyze the drinking water samples for Lead:

Drinking Water Sample Preparation	USEPA Method 200.2
Lead by AA-Graphite Furnace	SM 3113B

Each sample was preserved, at EHS, LLC, with nitric acid to reduce the pH to less than 2 as per USEPA Method 200.2.

Chain of Custody (“COC”) forms are used to document the history of sample possession from the time the sample containers leave their point of origin to the time the samples are received by the laboratory.

In Table 1 of this report we have listed water samples that are above 15 ppb.

TABLE 1

Holley CSD Transportation Center			
Sample ID	Water Source	Level Detected (PPB)	Remedial Suggestions
		None Detected	All outlets are below the NYSDOH Action Level

Please refer to the attached laboratory reports for specific analytical data and sample locations throughout the school. If you have any questions, please contact me at (585) 454-1060. We appreciate the opportunity to provide you with our professional services.

Sincerely,



Ted Knapp
Project Manager
Envoy Environmental Consultants, Inc.



Environmental Hazards Services, L.L.C.
 7469 Whitepine Rd
 Richmond, VA 23237
 Telephone: 800.347.4010

Analysis By: National Testing Laboratories, LTD

Client: Envoy Environmental
 57 Ambrose St
 Rochester, NY 14608

Lead in Drinking Water Analysis Report

Report Number: 16-10-00474

Received Date: 09/27/2016
 Reported Date: 10/05/2016
 Sampled By: Geoffrey Siebert
 Tech Certification #:

Project/Test Address: Holley Transportation Center; Holley, NY 14470

Client Number:
 33-5448

Laboratory Results

Fax Number:
 585-454-1062

Lab Sample Number NTL Sample ID	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
16-10-00474-001 741510	TB-1-IM-01	09/20/2016	ICE MACHINE	<1	10/02/2016	
16-10-00474-002 741511	TB-1-KS-02	09/20/2016	KITCHEN SINK	1	10/02/2016	
16-10-00474-003 741512	TB-1-BS-03	09/20/2016	BATHROOM SINK	3	10/02/2016	
16-10-00474-004 741513	TB-1-BS-04	09/20/2016	BATHROOM SINK	2	10/02/2016	
16-10-00474-005 741514	TB-1-BS-05	09/20/2016	BATHROOM SINK	2	10/02/2016	
16-10-00474-006 741515	TB-1-BS-06	09/20/2016	BATHROOM SINK	4	10/02/2016	
16-10-00474-007 741516	TB-1-DW-07	09/20/2016	DRINK WATER	<1	10/02/2016	
16-10-00474-008 741517	TB-1-BS-08	09/20/2016	BATHROOM SINK	3	10/02/2016	
16-10-00474-009 741518	TB-1-KS-09	09/20/2016	KITCHEN SINK	<1	10/02/2016	

Environmental Hazards Services, L.L.C

Client Number: 33-5448

Report Number: 16-10-00474

Project/Test Address: Holley Transportation Center; Holley, NY 14470

Lab Sample Number NTL Sample ID	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
------------------------------------	---------------------	--------------------	---------------------	-----------------------------	------------------	-----------------

Method: SM 3113B

NTL Lab ID: NY- 11467

Reviewed By Authorized Signatory:



Tasha Eaddy

QA/QC Clerk

Sample Results denoted with a "less than" (<) sign contains less than the reporting limit which is 1 ppb.

The EPA Maximum Contaminant Level for Lead in Drinking Water is 15ppb. The results herein conform to NELAC standards, where applicable, unless otherwise narrated on this report. Results represent the analysis of samples submitted by the client. Sample location, description, field parameter results, etc., were provided by the client. This report cannot be reproduced, except in full, without written approval of Environmental Hazards Services, L.L.C.

LEGEND ug/L= micrograms per liter ppb = parts per billion

208 3446 9/20/16



EHS Laboratories
 Environmental Monitoring Services, LLC
 200 Washington St
 (603) 342-0978
 (603) 342-0977 (fax)
 Manchester, NH 03102

WaterSmartPro
EMAILED LEAD ONLY
 Chain-of-Custody
 SEP 20 2016 by National Testing Laboratories

**-For Lab Use Only -
 SEND SAMPLES
 TO:
 556 S. Mansfield St.
 Yonkers, NY 10710**

Company Name: Envoy Environmental Address: 57 Ambrose Street City/State/Zip: Rochester, NY 14608
 Phone: () 585-454-1060 Fax: () 585-454-1062 Email: tknapp@envoyenv.com Alt. Number:
 Project Name/Testing Address: Hollen Transportation Center City/State/Zip: Holley, NY Zip: 14470 App. of Inspector:
 Collected by: Geoffrey Siebert Certified: Waiting for availability: Date: 9.20.2016
 Purchaser Order Number: Requested by: Paul Sw

ALL SAMPLES BELOW SHOULD BE ANALYZED FOR LEAD IN DRINKING WATER
SAMPLES SUBMITTED ARE SUBJECT TO THE NATIONAL TEST LAB. POLICIES AS APPLICABLE WITH IMPROPER APPOINTMENT NUMBERS.
PLEASE PROVIDE A CHAIN-OF-CUSTODY FORM AND A LABEL EXEMPTED ON THIS CHAIN OF CUSTODY.

No.	Client Sample ID	Collection Location (Ex: Kitchen Sink)	Collection Date	Collection Time	Amount	Field Parameters	Temperature of Sample Collection
1	TB-1-IM-01	Foe Machine	9.20.16	0500		VH	74/510
2	TB-1-KS-02	Kitchen Sink	9.20.16	0501			511
3	TB-1-B5-03	Bathroom Sink	9.20.16	0502			512
4	TB-1-B5-04	B5	9.20.16	0503			513
5	TB-1-B5-05	B5	9.20.16	0504			514
6	TB-1-B5-06	B5	9.20.16	0505			515
7	TB-1-DRINK-07	Drink Water	9.20.16	0506			516
8	TB-1-B5-08	B5	9.20.16	0507			517
9	TB-1-KS-09	KS	9.20.16	0508			74/518
10							

16-10-00474

Due Date:
 10/11/2016
 (Tuesday)
 ER MC

ST 16-09-04237

Submitted by: Paul Sw Date: 9-27-16
 Testing Number: 12 5FC 007904578 3700 Time: 0225
 NTL Lab ID Number

Client: Holley Central School District
Location: Transportation Building
Work Performed: Water Testing
Date: September 20, 2016
Job Number: E16-1414

